



FINAL DESIGN REPORT April, 2022

Division :
Office Building





TABLE OF CONTENT

1.0 <u>Executive Summary</u>	4
2.0 <u>Team Summary</u>	5
2.1 Team Members	
2.2 Approach	
2.3 Background of Lead Institute	
2.4 Faculty Lead	
2.5 Industry Partners	
3.0 <u>Documentation of Design Process</u>	8
3.1 Design Process Flow	
3.2 Tools Used	
3.3 Challenges Faced and Approaches taken to Overcome	
4.0 <u>Project Background</u>	10
4.1 Project Partner	
4.2 Brief description of the project	
4.3 Context and Market Analysis	
4.4 Special requirements of the Project Partner	
4.5 Building Area Program	
4.6 Construction Budget	
5.0 <u>Performance specifications</u>	12
5.0 <u>Goals</u>	13
6.0 <u>Documentation of Design Process</u>	14
6.1 <u>Pre-Design Analysis</u>	
6.2 <u>Thermal Comfort analysis</u>	
6.3 <u>Design and form Development</u>	
6.4 <u>Zoning</u>	
6.5 <u>Design Challenge and Approach</u>	
7.0 <u>Design Documentation</u>	16
7.1 <u>Architectural Design</u>	
7.2 <u>Energy Performance</u>	
7.3 <u>Water Performance</u>	
7.4 <u>Engineering Design and Operation</u>	
7.5 <u>Health and Wellbeing</u>	
7.5 <u>Innovation</u>	
7.6 <u>Resilience</u>	
7.7 <u>Affordability</u>	
7.8 <u>Scalability and Market Potential</u>	
8.0 <u>Pitch to Project Partner</u>	42
9.0 <u>References</u>	43



LIST OF FIGURES

Fig 1: Team Members
Fig 2: Faculty Members
Fig 3: Design Process Flow
Fig 4: Tools Used
Fig 5: Google Earth Image of Site
Fig 6: Site Plan
Fig 7 : Goals and Strategies
Fig 8: Psychrometric Chart
Fig 9: Adaptive Comfort band for mixed mode of office building
Fig 10: Thermal simulation - proposed case
Fig 11: Adaptive Comfort band overlay on annual simulation graph
Fig 12: Relative Humidity Graphs
Fig 13: modes of operation throughout the year
Fig 14: Design Development
Fig 15: Zoning
Fig 16: Site Analysis
Fig 17: Form Development
Fig 18: Floor Plans
Fig 19: Longitudinal sections
Fig 20: Rendered exterior view
Fig 21: Transverse section
Fig 22: design strategies
Fig 22: Path to net zero buildings
Fig 23: Comparison between AAC blocks
Fig 24: Wall and Roof Details
Fig 25: Comparison between VRF and Radiant Cooling Systems
Fig 26: Solar Irradiance simulations
Fig 27: Solar PV Layout
Fig 28: Schematic working of PV panels
Fig 29: Water cycle diagram
Fig 30: Unused greywater
Fig 31: Harvested Rain Water
Fig 32: Storage and Demand
Fig 33: Water consumption Comparison
Fig 34: Tank sizing
Fig 35: Section of water fixtures
Fig 36: Black water flow chart diagram
Fig 37: Rainwater flow chart
Fig 38: Plan showing water fixtures
Fig 39: Green planter strip drain detail
Fig 40: Foundation footing and column layout
Fig 41: Two way structural slab
Fig 42: Bending moment analyses of structural beams and columns
Fig 43: Beam and column reinforcement detail
Fig 44: Detail of radiant cooling system integrated in structural slab
Fig 45: Footing Detail
Fig 46: Attachment detail of hePEX Tubing
Fig 47: Lighting layout Plan
Fig 47: Analysis of lighting layout
Fig 48: Equipment Layout Plan
Fig 49: Operational zones for air conditioning for typical office floor
Fig 50: Section - Air Conditioning system
Fig 51: HVAC Detail
Fig 52: Slab detail of radiant cooling
Fig 53: Water purification system



Fig 54:Section- water purification system
Fig 55:Window detail - southern Facade
Fig 56:Vertical shading device - southern window
Fig 57:Types of plants used
Fig 58:Assessment of site angle of occupants
Fig 59:Interior view of workstation
Fig 60:Plan of irresistible staircase
Fig 61:Daylight illuminance levels
Fig 62:sDA Analysis
Fig 63:ASE, UDI and DAA
Fig 64:Front elevation showing noise absorbing panels
Fig 65:Process of electricity generation
Fig 66:Irresistible staircase elevation
Fig 67:Terracotta tiles
Fig 68:Interior view of irresistible staircase
Fig 69:Resilience strategies
Fig 70:Fire Escape Layout
Fig 71: Recovery Plan
Fig 72:Operational Cost and financial breakup
Fig 73:Comparison of base case and proposed case
Fig 74:Maintenance cost over 10 yrs for VRF vs Radiant Cooling
Fig 75:Radiant Cooling VS VRF Cooling System
Fig 76:Comparison of brick and AAC costing
Fig 77:Corridor layout
Fig 78:Potential Target Market
Fig 79:Irresistible staircase view
Fig 80:Exterior View
Fig 81:Exterior view
Fig 82:Flow chart of green building

LIST OF TABLES

Table 1: Area Programme
Table 2:Base vs Proposed - Construction Budget
Table 3:Perforation Specification
Table 4:IMAC - MM 90% acceptability comfort bands
Table 5:Envelope optimization for thermal comfort
Table 6:U values
Table 7:Solar radiation and electricity generation
Table 8:Water Balance
Table 9:Per capita consumption
Table 10:Blackwater and greywater generation
Table 11:Water Harvesting sources
Table 12:Municipal supply and storage size
Table 13:Water consumption per day
Table 14:Base case water consumption as per NBC
Table 15:Proposed case per capita consumption
Table 16:Daily water consumption
Table 17:Flow rate of fixtures
Table 18:Rate of lighting fixtures
Table 19:Lighting load calculation
Table 20:Rate of equipment used
Table 21:Equipment load calculation
Table 22:Cooling load calculation
Table 23:HVAC Equipment
Table 24:Preventive maintenance
Table 25:Fire safety requirements
Table 26:Cost analysis for circuit analysis



EXECUTIVE SUMMARY

"Businesses, governments, and NGOs hold the key to this transformation, but they must commit to aggressive action. It is possible to create a world in which every single building produces zero carbon emissions, but we must start today."

- Terri Wills, CEO of the World Green Building Council

The building sector, which is responsible for global emissions roughly equivalent to that of China, is in a dire need of transformation from its norm. We, the Team Ecocult as part of the Solar Decathlon India, have taken up this opportunity to try and design a net-zero-energy-water building for Team Global Logistics' new regional office in Chennai.

This project, SAT- PRANALI, is a G+4 story build-own/lease operate a commercial building, whose 3rd and 4th floors are going to be the office for Team Global, while the 1st and 2nd floors are planned to be rented out to their sister companies. Our aim was to provide the most cost-effective net-zero energy-water solution by integrating the various infrastructural needs of the project by working on various aspects of design, production, and execution.

With careful consideration of all the building science principles and affordability, by carrying out pre-design comfort & energy simulation we developed an optimized building massing having a huge potential for obtaining thermal comfort through natural lighting and operating the building on mixed-mode ventilation.

With a built-up area of **2486.12 sqm**, our final building design has been able to achieve an EPI of **45 kWh/sqm/year**, (a significant reduction of **56.5 %** from the GRIHA benchmark) achieving its net-zero target through solar PV generation **120485 kWh/day**. The design is also Net-zero water, combining efficient water consumption measures coupled with rainwater harvesting and wastewater recycling systems. Thus, the proposal is able to achieve a **62.8%** consumption reduction from the base case and Water Performance Index of **14.6Lpd** due to on-site rainwater and stormwater management and sewage treatment.

With each direction having its own constraints, the façade has been designed based on the requirement and with the thought of how it can cater to the indoor comfort need along with the appearance and aesthetic factors. By properly calculating Wall-Window Ratio (WWR), we have achieved IMAC mixed-mode ventilation with **30%** natural ventilation and **100%** comfortable operating hours.

Through the constant back and forth process, an initial search and exploration of all possible options, and setting the goals right, the focus has been to reduce not only energy & water consumption but also to address the well-being of users and the challenges of affordability & marketability, resulting to the proposal whose incremental construction cost is increased by **3.7%** from the base case, but in long run ,the proposal proves to be efficient than the base case.



INDUSTRY PARTNERS

Blue Star is India's leading air conditioning and commercial refrigeration company along with other businesses which include marketing and maintenance of imported professional electronics and industrial products and systems.



BLUE STAR

DOCUMENTATION OF DESIGN PROCESS





Fig 3 : Flow of Design Process



Team Ecocult followed an integrated design approach by establishing the goals of each contest and their interrelations. The design process started with understanding the site and its strengths through SWOT analysis. This was further integrated with a climate analysis and understanding of the micro-climate of Mylapore, Chennai.

Shared with me > SD-2021



Constant weekly meetings with the team were scheduled, to strengthen the process and achieve the goals. The minutes of meetings were recorded and proper planning of weekly goals and targets was done to avoid end delays. All the research done was added to the drive for future references.



Fig 4 : Tools Used

CHALLENGES FACED & APPROACH TAKEN TO OVERCOME:

The team faced constant difficulty in finalizing the best solution among the shortlisted options. Further meetings were scheduled with various specialists and consultants to guide us in the selection process of the best solution among the shortlisted possible solutions. Simulations were run regularly to compare base cases and shortlisted system efficiency to finalize one particular option. We would like to take this opportunity to thank **Ar. Indranil Bhattacharya** (BRAE Consulting Services Pvt. Ltd), **Mrs. Mini Sastry** (Consultant at IFC), **Mr. Suresh K Murthy** (Dean of RVCA) and **Mr. Saikat Banerjee** (Pinnacle Consulting Engineers) for providing guidance to the team in this journey.



PROJECT BACKGROUND

PROJECT NAME: SAT-PRANALI

PROJECT PARTNER: TEAM GLOBAL

Team Global is an integrated Logistics services provider headquartered in Mumbai, India. They offer services in multiple segments of logistics Viz. Sea Freight, Airfreight, Project Cargo Transportation, Cargo Terminals and Coastal Shipping. Being a Non-govt company, incorporated on 25 Apr 2005; it has 18 offices in India, Bangladesh, Kenya and Tanzania. (<https://www.teamglobal.in/>)

NAME & DESIGNATION OF KEY INDIVIDUAL INVOLVED: Vivek Kele, Director at Team Global Logistics Pvt Ltd

BRIEF DESCRIPTION OF THE PROJECT: Team Global wanted to open its regional office in Chennai, for which they had acquired a plot of 8400 sq. ft in P.V Kovil Street. Their intent is to create an eco-sensitive building while availing maximum FSI. Being a build-own/lease-operate building, two floors will be utilized by the Team Global and the other floors are to be rented out to their sister companies.

LOCATION: Mylapore, Chennai

LATITUDE: 13° 2'33.77"N

LONGITUDE: 80°16'28.99"E

CLIMATE ZONE: Warm & Humid

PROFILE OF OCCUPANTS: White-collar workers

HOURS OF OCCUPATION: 9 am – 5 pm

CURRENT STATUS OF THE PROJECT: Waiting for approval (was on hold due to pandemic)



Fig 5 : Google Earth image of the site

CONTEXT

The site is located on a busy street with a city central mall (140m away) on the opposite side, and right next to the Mediscan building. While the shoreline is 815 m away, the Gandhi beach is just 582 m from the site on the eastern side. On the southern side of the site, there is a railway line and canal as well.




Fig 6 : Site Plan



SPECIAL REQUIREMENTS OF THE PROJECT PARTNER:

Since this building is designed to be the south zone regional office for Team Global, the client has requested for the logo to be displayed on the West side facing the road.

AREA STATEMENT

As per Tamil Nadu combined development building rules, the site is classified under CBA, hence there are no side and rear setbacks. The front setback is left based on the road width. The maximum FSI allowed is 3.15

SITE AREA	780.67 sqm
PERMISSIBLE BUILT UP AREA	2578.45 sqm
PROPOSED BUILT UP AREA	2486.12 sqm
GROUND COVERAGE	594.54 sqm
ROOF AREA	516.67 sqm

- Air-conditioned area
- Non- air-conditioned area

SL NO	PARTICULARS	NOS.	AREA(sq.m)	TOTAL AREA(sq.m)
1	RECEPTION / WAITING AREA	4	28.4	113.6
2	TEAM HEADS CABIN	4	18.3	73.2
3	MEETING ROOM	4	20	80
4	MANAGER'S CABIN	4	13.24	52.96
5	ASST. MANAGER'S CABIN	4	12.46	49.84
6	WORKSTATIONS			
6.1	FIRST FLOOR	1	186.4	186.4
6.2	SECOND FLOOR	1	186.36	186.36
6.3	THIRD FLOOR	1	175.25	175.25
6.4	FOURTH FLOOR	1	165.58	165.58
7	BMS ROOM	1	13	13
8	SERVER ROOM	4	10.76	43.04
10	ELECTRICAL ROOM	1	17	17
11	STAIRCASE 1	5	21.9	109.5
12	STAIRCASE 2	5	25.4	127
13	LIFT	5	4.6	23
14	LIFT LOBBY	5	9	45
15	SHAFTS			30
16	TOILETS	4	38	152
17	PANTRY	4	18.6	74.4
18	PASSAGE	4	14	56
19	PARKING	1	516.67	516.67
20	STORAGE	4	12.5	50
TOTAL				2,486.12

Table 1 : Area Programme

CONSTRUCTION BUDGET

Project Summary						
			Baseline Estimate (Project Partner / SOR basis)		Proposed Design Estimate	
			Amount (Rs Millions)	%	Amount (Rs Millions)	%
S.No.	Particulars	Definition				
1	Land	Cost of land purchased or leased by the Project Partner	68.84	46.70%	68.84	46.70%
2	Civil Works	Refer Item A, Civil works in Cost of construction worksheet	49.32	33.50%	49.22	33.40%
3	Internal Works	Refer Item B, Civil works in Cost of construction worksheet	5.71	3.90%	5.93	4.00%
4	MEP Services	Refer Item C, Civil works in Cost of construction worksheet	8.62	5.90%	13.23	9.00%
5	Equipment & Furnishing	Refer Item D, Civil works in Cost of construction worksheet	2.62	1.80%	2.62	1.80%
6	Landscape & Site Development	Refer Item E, Civil works in Cost of construction worksheet	0.17	0.10%	0.63	0.40%
7	Contingency	Amount added to the total estimate for incidental and miscellaneous expenses.	7.01	5.00%	7.27	5.00%
TOTAL HARD COST			142.29	96.90%	147.74	100.40%
8	Pre Operative Expenses	Cost of Permits, Licenses, Market research, Advertising etc	1.38	0.90%	1.38	0.90%
9	Consultants	Consultant fees on a typical Project	3.58	2.40%	3.58	2.40%
10	Interest During Construction	Interest paid on loans related to the project during construction	-	0.00%	-	0.00%
	TOTAL SOFT COST		4.96	3.40%	4.96	3.40%
	TOTAL PROJECT COST		147.25	100.00%	152.7	103.70%
	Total Project Cost per Sq.m of Built-up Area		72,183		74,853	

Table 2 : Base vs Proposed - Construction Budget



PERFORMANCE SPECIFICATION

GENERAL	
Built up Area	2486.12 sqm
Electricity Rate	8 INR/kWh
Average occupant density	10m ² / person
Building Occupancy Hours	9:00am - 5:00pm
ENVELOPE	
Wall assembly U value	0.22 W/m ² .K
Roof Assembly U value	0.21 W/m ² .K
Window U value	2.2 W/m ² .K
SHGC	0.5
VLT	61%
Exterior Shading Device	Horizontal shading device with vertical fins and plantation boxes
HVAC	
System Type	Radiant Cooling System with DOAS
Mixed Mode Strategy	Windows are open when operative temperature lies within the IMAC thermal comfort band below 29 deg. This is possible during the months of November, December and January
Cooling Capacity	37.23 TR
Operation Hours	9:00am - 5:00pm
LIGHTING	
Interior Average Lighting Power Density	0.71 W/ft ²
RENEWABLE ENERGY	
Type	Monocrystalline Photovoltaic Panels
Efficiency	19.20%
Generation Capacity	120485 kWh
Installed Capacity	80.1 kW
EPI	
Proposed EPI	45 kWh/ sqm per year
EPI Breakdown by use	
Cooling	25.24kWh/ sqm per year
Lighting	3.33kWh/ sqm per year
Equipments	14.69kWh/ sqm per year
WATER SYSTEM	
Total Daily Consumption	3368 Lpd
Domestic Requirement	3277.064 Lpd
Flushing Requirement	90.936 Lpd
Treated Black-water	5,06,827 L/year
Treated Grey-water	7,23,335 L/year
Total Treated Water	12,30,162 L/year

Table 3 : Performance Specification



GOALS



Architectural Design

To design a building that achieves a balance between form and function. **(Effective implementation of passive design strategies).** Efficient handling of the high humidity levels by wise use of air movement across the building. **(Achieved using Double skin on western façade and usage of shading devices on southern façade to reduce the heat gain).** An “irresistible staircase” provided for the health and well being of the employees as a buffer zone.



Energy Performance

To achieve a net-zero energy building with a target EPI of 54 kWh/sqm/year (GRIHA benchmark = 108 kWh/sqm/yr)
(Net site energy = 1,24,997 kWh; Achieved EPI = 45 kWh/sqm/year)



Water Performance

To achieve a net-zero water building. Target Water Performance Index (WPI) < 45 Lpd (Base value –from NBC). **(Achieved WPI = 16.4 Lpd)**
To reuse and recycle greywater and treat black water efficiently on site. **(Greywater - evapotranspiration & infiltration; Blackwater - composting unit)**



Resilience

To create a pandemic proof design, and have all the required backup prepared in case of any emergency.
(The building can sustain with the energy produced through solar panels and has water backup for 17 days.)



Health & Wellbeing

To achieve 100% comfortable operating hours as per IMAC. **(Achieved)**
To provide an effective ventilation system and ensure good indoor air quality and provide visual comfort and well-being. **(Achieved)**



Affordability

Adapting cost effective strategies to reduce the construction cost and decrease the life cycle cost by 30%. **(Achieved 34.6% reduction)**



Communication

To create awareness among peers in the architecture and the general public about ‘net’-zero-energy buildings and sustainable methodology. **(Official Instagram - Team ECOCULT: Impressions - 7422 accounts; Reach – 3434 users; 107 accounts engaged)**



Safety & Security


Physical protection of the assets and occupants of the office building from man made or natural accidents. **(Incorporation of fire protection system and placement of First aids for emergency usage)**

Fig 7 : Goals & Strategies



PRE-DESIGN ANALYSIS

The location of the project is in Chennai. It is classified as Aw. Tropical wet and dry or savanna type according to Köppen– Geiger climate zone. A detailed climatic study was conducted to understand the combination of strategies that could be adopted to enhance the building's performance and achieve 100% comfortable operational hours. Considering the relative humidity levels to be >65% (monthly average), and the Cooling Degree days (CDD) for Chennai as 4108 hours, that is, 47% annually, cooling and dehumidification are considered very essential for this type of climate.



Source: Givoni Bioclimatic chart – AndrewMarsh.com for Chennai

Fig 8 : Psychrometric Chart

The IMAC (India Model for Adaptive Comfort) is developed based on thermal comfort surveys of office buildings across India. Climate analysis shows that there is a potential for utilizing favourable outdoor environmental conditions for about 7.5% of the operational period. And for about 49%, comfortable hours can be achieved through passive design strategies and natural ventilation. Hence the building is designed for a mixed-mode operation. According to IMAC, for mixed-mode buildings, the 90% accessibility is 3.5°C from the neutral temperature.





Fig 9 : Adaptive Comfort Band for Mixed mode office building as per IMAC , for Chennai

By introducing an elevated airspeed of 0.7m/s, the upper comfort threshold is further increased by 2.5°C as given by ASHRAE 55-2017. The increased airspeed is achieved through ceiling fans which allows them to adjust the temperature threshold by 2.5°C, providing comfortable hours during unconditioned times.

(Calculated using CBE Thermal comfort tool)


Operative temperature = (0.25 x DBT (30-day running mean) +17.87




Natural Ventilation



Increased Air velocity at 0.7m/s



Passive design strategies



Cooling and dehumidification




Thermal Comfort Analysis

The use of low thermal conductivity materials, envelope optimization, efficient WWR and natural ventilation helped in decreasing the internal heat gain by 70 % (from the base case).

Internal heat gains due to office equipment and human metabolism and solar heat gains lead to an increase in the operative temperature indoors by about 1-2.5 degrees Celsius. However, about 1000 operational hours lie under the comfort band with 90%acceptability as shown in Figure 11.



Figure 10: Thermal simulation (proposed case)



Month	Mixed Mode buildings Max. Temp. Min. Temp.		Thermostat set point
Jan	28.36	21.44	28.2
Feb	28.69	21.44	28.1
Mar	29.13	22.21	29.4
Apr	29.69	22.77	29.6
May	30.31	23.39	30.1
Jun	30.53	23.61	30.3
Jul	30.00	23.08	29.8
Aug	29.75	22.83	29.6
Sep	29.66	22.74	29.7
Oct	29.41	22.49	30.0
Nov	29.01	22.09	29.7
Dec	28.63	21.71	28.6

Table 4: IMAC - MM 90% acceptability comfort bands

Table 5: Envelope optimization for thermal comfort




Fig 11: Adaptive Comfort Band overlay on Annual simulations graph




Fig 12: Relative Humidity graphs for 1st Jan, Feb, Nov and Dec




Fig 13: Modes of operation throughout the year

The simulations show that for about 30% of the year, the indoor temperatures lie under the comfortable bands and cooling + dehumidification is required for the rest of the year to achieve 100% comfortable hours.




DESIGN DEVELOPMENT

Larger cut-out for more functionality. Controlled staggering of west facade.

Cut-outs for natural light. Staggering of the western facade for self-shading.

Ground-level free for air movement & resilient measuring case of flooding



Wedging of southern facade for free air circulation and thermal comfort & green facade towards west and east.

Green wall with a recess on the northern side for maximum daylight. Courtyard on the eastern side will green wall.

Consecutively increasing recession on the northern facade to maximize daylight.

Fig 14 : Design development

Site following CBA setback

Permissible built up area

Ground floor raised above plinth

Cutouts and removing the excess built- up to maximise daylighting




Fig 17: Form development



Fig 15 : Zoning




Fig 16: Site Analysis

Building Orientation

The orientation of the building is along the long axes in the east-west direction.

The longest façade faces north and south directions along with a short wall facing the east and west direction as per the climatic condition on the site.



Plan at level 1 & 2



Plan at level 3



LEGEND

1. Reception and lobby
2. Fire Staircase
3. Lift Lobby
4. Lift
5. BMS Room
6. Storage
7. Manager's cabin
8. Conference room
9. Assistant cabin
10. Open workstation
11. Cabin 1
12. Cabin 2
13. Washrooms
14. Irresistible staircase
15. Pantry
16. Balcony

- Public
- Private

Fig 18 : Floor Plans



Fig 19 : Longitudinal Section



Fig 20: Rendered exterior view

DESIGN

Northern Facade - Maximizing daylight and allowing for cross ventilation.

Southern facade - Maximizing airflow into the building and controlled light without much thermal heat gain.

Western facade - Double skin with green wall facade and noise absorbing panels to generate electricity.

Eastern facade - Irresistible staircase with planter boxes to provide airflow into the building that reduces the heat gain into the building.





Fig 21 :
Transverse
Section




DESIGN




PROGRAM

- Team Global Office
- Other Rental Offices
- Parking



VERTICAL TRANSPORTATION

- Fire Tower : Staircase, Lift
- Irresistible Staircase



SHADING DEVICES

- Horizontal shading device with vertical shades integrated with planter boxes



FRONT ELEVATION


- Noise absorbing panels integrated on front facade that converts into electrical energy

ENERGY




ENERGY POTENTIAL

25 year technology of monocrystalline solar panel




LIGHTING & EQUIPMENT

100% renewable energy on site is used



NATURAL VENTILATION


Cross flow openable windows & balconies



MECHANICAL VENTILATION


Radiant cooling system with DOAS system

WATER




RAIN WATER STORAGE

Rain water on site is collected to meet the demands



FRESH WATER

Rest of the the demand is met by municipal supply, surface runoff & ground water



WASTE COMPOST

Composting units for treating black-water.



GREY WATER TREATMENT

100% treatment on site by Evapo-trapiration & Infiltration

Fig 22: Design Strategies



ENERGY PERFORMANCE

PASSIVE DESIGN

- Envelope Optimization
- Shading
- Irresistible Staircase to discourage elevator use
- Natural Ventilation

Target Energy

Performance Index

GRIHA benchmark for EPI = **108**

kWh/sqm per year

Achieved EPI = **45** kWh/ sqm per year

EFFICIENCY

- Maximize Daylighting
- Efficient equipment
- Efficient lighting fixtures

OPERATION

- Radiant slab cooling with DOAS
- Mixed mode operation
- High-performance glass
- High-performance walls & roof




Fig 23: The path to net zero building

Building massing and orientation, as well as insulated walls, control heat gain. The building's windows face south and north to improve daylighting and solar control. Several simulations and analyses were done to get the final proposed design.

Our goal to achieve net-zero energy building is done by using several passive design strategies, efficient lighting fixtures and equipment and an optimized HVAC system

In targeting net-zero energy we calculated the amount of energy falling on-site from the sun and noise from the streets that is converted into electrical energy using high technology & innovative methods.

In the context of lying in a hot & humid climate, the major concern was to minimize heat gains in the building. This was achieved by using natural ventilation for passive cooling and a radiant cooling system with DOAS.

Simulation software made it easy to analyze the design to get better results. Daylight analysis also helped us in massing the project.



Envelope Optimisation

Building massing and orientation, as well as insulated walls, control heat gain. The building's windows face south and north to improve daylighting and solar control. Several simulations and analyses were done to get the final proposed design.




Fig 24 :Wall and Roof details




Fig 23: Comparison between AAC blocks with XPS and thermo-jute with wood framing

Façade Direction	WWR
North	40%
South	25%
East	10%
West	4.5%

	WALL	ROOF	WINDOW
STANDARD DESIGN	Outer cement plaster 0.01m +XPS 0.07m+ brickwork 0.2m + inner cement 0.01m U VALUE - 0.4	Cement plaster 0.01m +XPS 0.00m+ RCC slab 0.15m + inner cement 0.01m U VALUE - 0.33	6mm (solar control glass) - 12mm air gap - 6mm clear glass U VALUE - 3
PROPOSED DESIGN	Outer cement plaster with AAC 0.225m +XPS 0.08m+inner cement 0.012m U VALUE - 0.22	Outer cement plaster 0.01m +XPS 0.015m+ RCC slab 0.15m + inner cement 0.012m U VALUE - 0.21	Vertical sealed double glazed window - 20mm air gap - ordinary glass of medium coloured having SHGC 0.22 U VALUE - 1.95

Table 6 : U- Values

HVAC Optimisation




Fig 25: Comparison between VRF and Radiant Cooling with DOAS

HVAC optimization has been done with respect to the functionality in spaces which includes workstations, cabins, conference rooms, reception and manager and assistant cabins. Several analyses and simulations were done considering Baseline, VRF and Radiant Cooling with the DOAS system that helped in energy reduction.

DOAS- dedicated outdoor air system
VRF- Variable refrigerant flow

VRF



Radiant Cooling with DOAS





Solar Potential

The site receives an average solar irradiance of 5.5kWh/sqm per day which promises a positive solar potential. The horizontal terrace receives maximum solar irradiance compared to the building facade. The solar panels are placed on the terrace as well as mumty to meet the demands of energy requirements. PVWatts was used to calculate the solar energy generated on the site. Along with a solar array, sound-absorbing panels on the west facade have the capacity to generate 3kW and energy savings of 4512kWh.




Fig 26: Solar Irradiance simulations





Fig 28: Schematic working diagram of PV Panels





Fig 27: Solar PV Layout

MODULE SPECIFICATIONS

Loom Solar Panel

Size: 2131 x 1047 x 35 mm
Monocrystalline solar panel
Series: (12*6) * 2 of 144 cells
Module Efficiency : 19.2%
Output Power: 530 watts
Tilt angle: $(13 * 0.87) + 3.1 = 15^\circ$
Number of panels: 216




Month	Solar Radiation (kWh/m2/day)	Electricity Generation (kWh)
JAN	6.6	12359
FEB	6.75	11275
MAR	7.25	13210
APR	6.74	11791
MAY	5.85	10708
JUN	5.21	9308
JUL	4.74	8826
AUG	4.67	8742
SEPT	5.12	9202
OCT	4.87	8977
NOV	3.69	6843
DEC	4.84	9244
ANNUAL	5.53	120485

Table 7: Solar radiation and electricity generation



WATER PERFORMANCE



WATER CYCLE DIAGRAM

Fig 29: Water cycle Diagram

Months	Days in month	Rainfall (mm)	Effective rain (mm)	Harvested water (l)	Municipality water supply (l)	Primary demand (l)	Grey water generated (l)	Irrigation seasonal factor (%)	Irrigation Water demand (l)	Unused grey water (l)	Total fresh water demand (l)	Storage (l)
October	31	223	218	137422	68758	104408	61392	10%	604.5	51599.5	104408	120000
November	30	228	223	140574		101040	59412	10%	585	49935	101040	120000
December	31	113	108	68081		104408	61392	20%	1209	50995	104408	120000
January	31	17	12	7565	68758	104408	61392	20%	1209	50995	104408	120000
February	28	9	4	2522	62659	95146	55946	50%	2754.375	44818.625	95146	120000
March	31	11	6	3782	68758	104408	61392	50%	3022.5	49181.5	104408	120000
April	30	18	13	8195	66540	101040	59412	50%	2925	47595	101040	120000
May	31	48	43	27106	68758	104408	61392	100%	6045	46159	104408	120000
June	30	68	63	39651	66540	101040	59412	100%	5850	44670	101040	120000
July	31	70	65	40974		104408	61392	20%	1209	50995	104408	108770
August	31	99	94	59255		104408	61392	20%	1209	50995	104408	115822
September	30	110	105	66190		101040	59412	10%	585	49935	101040	120000

Table 8: Water balance



An effective water cycle has been developed to minimize daily fresh municipal demand. The usage of water-efficient fixtures has resulted in a 62.58% reduction from the base case. Rainwater harvesting was explored and implemented. This helped reduce the freshwater demand by more than 50%. Treated greywater is used as an alternate source of water for the non-potable purpose. In the monsoon months, extra grey water is used for ground recharge.




Fig 32 : Storage and Demand Harvested Rainwater




Fig 31 : Harvested Rain Water




Fig 30: Unused Grey Water

Per Capita daily consumption	Number of occupants	Total daily consumption	Grey water filter efficiency
16.84	200	3368	75%

Table 9: Per Capita Consumption

Months	Days in month	Generated black water	Generated Grey water	Filtered grey water
Oct	31	43016	61392	46043.928
Nov	30	41628	59412	44558.64
Dec	31	43016	61392	46043.928
Jan	31	43016	61392	46043.928
Feb	28	39200	55946	41959.386
Mar	31	43016	61392	46043.928
Apr	30	41628	59412	44558.64
May	31	43016	61392	46043.928
Jun	30	41628	59412	44558.64
Jul	31	43016	61392	46043.928
Aug	31	43016	61392	46043.928
Sep	30	41628	59412	44558.64
Total :		506827	723335	542501.442

Table 10: Blackwater and greywater generated

Water harvesting Sources	Area	Runoff coeff
Roof Surfaces	548.09	0.85
Hardscape areas	170	0.7
Softscape areas	130	0.35
Effective catchment area :	630.3765	

Table 11: Water harvesting sources

Municipality water supply (l/day)	4,436
Storage size (l)	120,000

Table 12 : Municipal supply and storage size

Water consumption point	Quantity	Liters/day
Occupants : {People x l/person}	200	16.84
Irrigation (max) : {m ² x l/m ² }	130	1.5
Cooling tower (max) : {Ton x l/Ton}	37.23	3

Table 13: Water consumption per day

Note: Due to the usage of the radiant cooling system, water consumption would be minimal. Water required at the time of commissioning the system is 4000 Litres.



Base Case :			
Per-capita consumption per day : 45 Lts			
Activities	Domestic (Lts)	Percentage	44.4% of 45 Litres
Handwash	4.5	10	
Drinking	1.98	4.4	
Kitchen/pantry	4.5	10	
Cleaning	9	20	
Activities	Flushing (Lts)	Percentage	55.6% of 45 Litres
Urinal flushing	13.5	30	
WC flushing	11.52	25.6	

Table 14: Base Case water consumption as per NBC

Proposed Case :			
Per-capita consumption per day : 16.84 Lts			
Activities	Domestic (Lts)	Percentage	97.3 % of 16.84 Litres
Handwash	0.9	5.3	80% reduction due to water efficient fixtures
Drinking	1.98	11.8	
Kitchen/pantry	4.5	26.7	
Cleaning	9	53.4	
Activities	Flushing (Lts)	Percentage	2.7% of 16.84 Litres
Urinal flushing	0	0	Zero water flush
WC flushing	0.46	2.7	Composting toilet : 1 cup per flush

Table 15: Proposed Case per-capita water consumption

Occupant's Activity	Percent usage	Quantity	Grey water	Black water
Hand wash	5.40%	181.872	100%	0%
Drinking	11.80%	397.424	0%	100%
Kitchen/Pantry	26.70%	899.256	0%	100%
Cleaning	53.40%	1798.512	100%	0%
Urinal flushing	0.00%	0	0%	100%
WC Flushing	2.70%	90.936	0%	100%

Table 16: Daily water consumption




Fig 34 :Tank Sizing

Overhead tanks

■ Freshwater
(Municipal + Treated rain water)

■ Treated Water
(Recycled grey-water +Surface runoff rainwater)
Fire water tank-10,000 Litres
Tanks for HVAC: 2 X 1000 Litre tanks for Chillers

Underground tanks

■ Freshwater
(Municipal + Treated rain water)

■ Treated Water
(Recycled grey-water +Surface runoff rainwater)
Fire water tank-1,00,000 Litres

Water consumption Comparison




Fig 33 :Water Consumption Comparison

Water saved in comparison to base case =62.58%

Image of the Sanitary fixture					
Sanitary fixtures	Sensor faucet	Health faucet	Composting foam flush toilet	Aqua-free Waterless Urinal	Kitchen faucet
Baseline water usage LPM (1 BAR PRESSURE)	4.31	8	6	2.2	8
Benchmark water usage LPM (1 BAR PRESSURE)	1.8	4	0.28	0	6
Cost (INR)	5500	1725	33,295	5900	2500
Company	Jaquar	Jaquar	Clivus Multrum	Hindware	Jaquar

Table 17: Flow rate of fixtures




Fig 35 : Section




Fig 36 : Black water flow chart diagram






Fig 37 : Rain water flow chart diagram



LEGEND	
	25mm dia. DOMESTIC WATER SUPPLY PIPE
	32mm dia. FLUSHING WATER SUPPLY PIPE
	110mm dia. SOIL CARRIER PIPE
	70mm dia. WASTE CARRIER PIPE

Fig 38 : Plan showing water fixtures

GREYWATER FILTRATION SYSTEM




Fig 39: Green planter strip drain field.

This system ensures that 100% of stormwater and building water discharge would be managed onsite. Any overflow is infiltrated into the ground through a green planter strip drain field.



ENGINEERING DESIGN AND OPERATION - Structures

The Structural Design of the Team Global office division building has been done in compliance with the soil condition and the Earthquake loads of Chennai, using STAAD.Pro software. The Design is an IS-456 Code complaint and has been done for M-30 Grade of concrete and Fe-550 Reinforcement.

The design employs 2 types of typical orthogonal footing and 2 types of typical column sections as 750mmX200mm and 600mmX200mm in the entire project.




Fig 46 : Attachment detail of hePEX Tubing




Fig 40 : Foundation footing and column layout




Fig 45 : Footing Detail




Fig 41 : Two way structural slab




Fig 44 : Detail of Radiant Cooling integrated in Structural Slab




Fig 43 : Beam and Column Reinforcement detail




Fig 42 : Bending Moment analyses of Structural Beams and Columns



Lighting Load Calculation


Images of lighting fixtures				
Type of lighting:	Suspended LED	Ceiling mounted LED(battens)	Ceiling downlight LED	Ceiling downlight LED 2
Company:	Philips	Philips	Philips	Philips
Average lumen received:	40000	20000	1000	2000
Wattage(W):	30	16	10.6	22

Table 18 : Rate of Lighting Fixtures

SI no.	Space Function	Target illuminance (lux)	Type of lighting	Company	Average lumen received	Watt (W)	Area	NOs.	Hrs per day	No. of days	Total hrs	Energy consumed annually (wh)
1	Reception/ waiting lobby	200	Ceiling downlight LED 2	Philips	2000	22	28.4	16	8	313	2504	869166.22
2	cabins	350	Suspended LED	Philips	4000	30	18.3	18	7	313	2191	1169446.25
3	Workstations	500	Suspended LED	Philips	4000	30	186.4	68	7	313	2191	4469640.00
4	Staircase	100	Ceiling downlight LED 2	Philips	2000	22	48	16	8	313	2504	881408.00
5	Lobby	100	Ceiling downlight LED 2	Philips	2000	22	9	4	8	313	2504	220352.00
6	Toilets	150	Ceiling downlight LED	Philips	1000	10.6	42	24	8	313	2504	637017.60
7	Pantry	200	Ceiling mounted LED(battens)	Philips	2000	14	18.6	4	1	313	313	17528.00
8	Storage	50	Ceiling downlight LED	Philips	1000	10.6	14	4	0.5	313	156.5	6635.60
9	Meeting Room	500	Ceiling mounted LED(battens)	Philips	2000	14	20	8	1	313	313	35056.00
10	Server Room	300	Ceiling downlight LED	Philips	1000	10.6	10.76	8	7	313	2191	185796.80
11	Passage	100	Ceiling mounted LED(battens)	Philips	2000	14	27	8	8	313	2504	280448.00

Total (Wh) :	8772494.47		Total (kWh) :	8772.49
---------------------	------------	--	----------------------	---------

Table 19 : Lighting load calculation

Software: Dialux evo





Fig 47 : Lighting Layout



Ceiling Reflectance = 55%
 Floor Reflectance = 70%
 Wall Reflectance = 80%
 Ext. Wall Reflectance = 75%

Fig 48 : Analysis of Lighting Layout



Equipment Load Calculation







Appliances	Cost in rupees	Power		Appliances	Cost in rupees	Power	
Farberware Classic FMO07ABTWHA Microwave oven	15,299	700		Dell Latitude series laptop	59,828	137	
Godrej 190 L 5 Star Inverter Direct-Cool Single Door Refrigerator	16,990	285		Havells Exhaust fan (Ventil air) @200mm	1290	32	
High Volume low Speed (HVLS) Fan HF-12 B5	20,000.00	750		HP SMART TANK 750 WI FI DUPLEXER PRINTER	23,020	0.1 watts (off); 1.10 watts (sleep)	

Table 20 : Rate of equipments used

SI No.	Appliances	Nos.	Wattage	No. of hours per day	No. of days	Energy consumed annually (kwh)
1	Laptop	144	35	7	313	11042.64
2	Printer (commercial)- Standby	8	30	2	313	150.24
3	Printer (commercial)	4	400	2	313	1001.6
4	Microwave	4	700	0.5	313	438.2
5	Refrigerator	4	285	24	313	8563.68
6	Water purifier	4	25	0.5	313	15.65
7	Projector	4	300	1	313	375.6
8	Water Pump	1	3000	8	313	7512
9	Lift	1	800	8	313	2003.2
10	Fan	16	750	7	90	7560
Total						38662.81

Table 21 : Equipment load calculation




Fig 48 : Equipment Layout Plan

HVAC Load Calculation

FLOOR	COOLING LOAD IN BTU/H			TOTAL TR	No. of hours per day	No. of days	Energy consumed annually kWh)
	SENSIBLE LOAD	LATENT LOAD	TOTAL LOAD				
1F	108105	21533	129639	10.8	8	223	19267.2
2F	74231	21533	95764	7.98	8	223	14236.32
3F	74231	21533	95764	7.98	8	223	14236.32
4F	104067	21533	125601	10.47	8	223	18678.48
TOTAL	360634	86133	446768	37.23	Total		66418.32

Table 22 : Cooling load calculation



PARTICULARS	STANDARD DESIGN	EFFICIENT DESIGN
SENSIBLE LOAD IN TR	45	30
LATENT LOAD IN TR	7	7
TOTAL COOLING LOAD IN TR	52	37
PLANT FOR SENSIBLE COOLING		
CHILLERS	25 TR AIR COOLED SCROLL CHILLERS - 2 No.S	18 TR AIR COOLED SCROLL CHILLERS - 2 No.S
CIRCULATION PUMPS	251 LPM/20M HEAD - 3 NO.S (2 WORKING + 1 STANDBY)	182 LPM/20M HEAD - 3 NO.S (2 WORKING + 1 STANDBY)
PLANT FOR LATENT COOLING		
TREATED FRESH AIR UNIT WITH DX COIL	2500 CFM X 1 NO.	2500 CFM X 1 NO.
CONDENSING UNIT FOR TFA	5.5 TR X 2 NO.S	5.5 TR X 2 NO.S

Table 23: HVAC Equipment




Fig 49: Operational Zones for Air-conditioning for typical office floor

1. Rautherm S pipe
2. Surface sensor
3. System controller
4. PRO-BALANCE® manifold
5. Chiller plant
6. Pump




Fig 52: Slab detail of radiant cooling




Fig 51: HVAC Detail



Fig 50 : Section: Air conditioning system




Fig 53: Plan Water Purification System

Water Purification System

Legend

- 1.UnderGround Tank
- 2.Filters
- 3.Carbon Filter
- 4.Chlorine Tank
- 5.UV Light Disinfectant
- 6.Pressure tank
- 7.Pump
- 8.Leachate Tank
- 9.Composting Units
- 10.Waterless Urinals
- 11.Composting Foam Flush Toilet
- 12.Over Head Tank

Wastewater treatment and reuse

It is estimated that 1387.6 litres of blackwater and 1980.3 litres of greywater are generated from the building every day. The wastewater is sent to the filtration room where greywater is passed through a series of water purification equipment. The surface runoff is infiltrated into the ground through a green planter strip drain field, which filters the water further through the process of evapotranspiration and infiltration, at the same time replenishing the groundwater.



Fig 54: Section -Water Purification system



HEALTH AND WELLBEING

The building is designed for a mixed-mode operation. It is naturally ventilated for about 30% of the operational hours and air-conditioned for the rest. This helps in achieving 100% comfortable operating hours throughout the year.

Optimizing the layout, zoning and the building allowed for better cross-ventilation of spaces and helped in maximizing the daylit spaces.




Fig 55 : Window detail section – Southern facade




Fig 56 : Vertical shading device – Southern windows



Fig 57: Types of Plants used

Façade Direction	WWR
North	40%
South	25%
East	10%
West	4.5%

A popular 1989 study conducted by NASA concluded that plants are natural air purifiers. The study showed that through photosynthesis, the plants would convert the carbon dioxide we exhale into clean oxygen. Plants are also capable of removing toxins from the air we breathe like PM5 and PM10.

Hence, the window detail is integrated with planter boxes towards the southern side. The box has been designed such that it is visible from the work plane level, that is, at 750mm above FFL.




Fig 58: Assessment of sight angle of the occupant


Plant varieties like Areca Palm, Raphis Palm, Schefflera Venulosa, money plant, the peace lily, the weeping fig etc. are used both indoors and outdoors which help in improving the air quality as well as provides visual comfort to the occupants. Some of the above-mentioned plants also help in absorbing noise from the surroundings without affecting the humidity levels.



Fig 59: Interior View of workstation

THE IRRESISTIBLE STAIRCASE:

For those occupants who are able, an “irresistible stair”, with fresh air, connection with nature and a break time hangout area, promote stair use, and human health and reduces the usage of lifts.



Time of usage: 8 AM, break time, HVAC running seasons and 7 PM



The design of the staircase and the interiors enhance human senses like sight, touch, smell and hearing.




Fig 60: : Plan of the irresistible staircase



The staircase to the east which is a little isolated from the workspace creates more like a buffer space for the employees of the office. The staircase design is intertwined with nature considering people’s health and visual comfort.



Mid landing is extended as a seating space of the staircase which acts as a pause point.



Planter boxes with plants (weeping fig) of low maintenance and a small tree in the center of the staircase well create a visual connection with nature on every floor.



For those occupants who are able, an “irresistible stair”, with fresh air, connection with nature and a break time hangout area, promote stair use, and human health and reduces the usage of lifts.



Silk Breathe Easy by Berger Paints eliminates lead, mercury and chromium from their paints and greatly reduced VOCs and the content of aromatics so that their products have no negative health impact. They are also anti-infection, anti-pollution and anti-bacterial and comes with a certified label by Singapore Green label.



Noise-Friendly Flooring: 1800mm high wall partitions help in separating the employees and reduce the overall noise to some extent as well.



LVT flooring is versatile alternatives thanks to its ease of maintenance and variety of design options. LVT flooring by itself boasts sound absorption qualities.




Fig 61: Daylight illuminance levels



Fig 62: sDA Analysis




Fig 63: Annual Sunlight exposure, Useful daylight illuminance and daylight Autonomy Analysis (Initial analysis for workspace zone on AndrewMarsh)



INNOVATION

NOISE ABSORBING PANELS

With an aim to achieve net-zero energy, team Ecocult proposes the idea of making use of a renewable source of energy where we intend to produce our energy on-site as an addition to the grid.

The solution proposed is to make "NOISE BASED POWER BANKS" that make use of the sound, converting it into electrical energy which is used for lighting up the front facade and also acts as a backup option when stored in batteries. We tried to achieve this in two ways, one with the concept of a Piezoelectric system, that uses unique crystals to convert sound wave energy into electrical energy (which can be adapted in form of panels for facades once developed, but in our case used in the compound wall), second by using the circuit system method that uses speaker/mic/sound sensor to absorb sound.




Fig 64: Front elevation




Figure 65.1: Sound absorbing panels




Figure 65.2: Energy conversion schematics

Size-**350mm x 350mm**
Voltage:12.5v
Amper :0.2A
Watts:**3kw**
Energy generated :**4512 KWH**




Figure 65: Process of electricity generation



TERRACOTTA BLOCKS

The site (Mylapore, Chennai) is in a hot and humid climate, the main aim is to reduce the temperature and maximize airflow into the building. So the idea is to use the terracotta block (300mm x 300mm) which tapers into a 150mm x 150mm void to help reduce the air temperature which in turn reduces the cooling load.

This block is placed along the wind direction. It enables faster construction and adds character to the facade.

In addition, the nature-centric hangout area promotes the use of the 'irresistible staircase, improving human health and reducing the usage of lifts.





Fig 66: Irresistible Staircase elevation




Fig 67: Terracotta Tile Block




Fig 68: Interior view of irresistible staircase





RESILIENCE

According to the hazard maps of India provided by BMTPC, hazards due to wind, cyclones and heat waves need to be considered.

Even though the site has not experienced any floods yet, it is better to design the building for floods as a few surrounding areas are prone to floods.

The site has a basic wind speed of 50 m/s.




Fig 69 : Resilience strategies

Sufficiency and Autonomy for critical functions

1. Water facility:

Water storage at a given point is **1,17,994 L**. Water consumption is **3,368 L/day** for working hours. Approximate, per day consumption = $3,368 \times 2 = 6,736 \text{ L/day}$ (Critical storage + Main storage)/ per day consumption = Days of Autonomy
 $1,17,994 / 6,736 = 17.5 \text{ days of Autonomy}$

2. Energy Efficiency:

Energy consumption per day is **1,13,853 kWh** which includes lighting, equipment and an HVAC system. The energy required is generated using Solar PV and sound-absorbing panels which are **1,20,485 kWh** from the PV array and **4512 kWh** from sound-absorbing panels.



Preventive Measures

Sl no.	Risk	Preventive Measures
1	Natural disasters	Preventive actions are considered for hazard resistant construction as mentioned earlier.
2	Slips and trips	All areas are well lit including stairs to prevent slips and trips. East-west clear central corridor helps with efficient circulation.
3	Stress and anxiety in working spaces	Open floor plan to make the working environment more transparent and democratic
4	Lack of preparation during a risk	<ul style="list-style-type: none"> Installation of a warning system and required drills for its use. Prior training of staff for various tasks in the emergency.

Table 24: Preventive Measures




Fig 70: Fire Escape Layout

Fire Safety Requirements

Sl no.	Types of Fire Protection	Description
1	Fire Extinguisher	2 per floor with travel distance not more than 12 m.
2	Wet Riser	Provided at all floors.
3	Yard Hydrant	Provided all around the building
4	Automatic detection and Alarm System	For entire building
5	Automatic Sprinkler System	For entire building
6	Underground and overhead water tank	UGT – 1,00,000 litres OHT – 10,000 litres
7	Fire shaft	1 Fire rated lift and staircase
8	Emergency Lights	At staircase landing and exit routes.

Table 25: Fire Safety Requirements

Address immediate well-being of occupants and provide necessary emergency services.



Examine the damage and provide solutions in decreasing order of priority



Provide safe and clean water supply obtained from critical and main water storage



Provide electrical supply from storage batteries for emergency services first and the remaining in the order of priority



Restore power supply by checking for damages in the distribution substations and supply lines



Clear obstructions on the western side (facing the main road) to permit transportation



Conduct repairs to restore communication and other utilities

Recovery Plan

Fig 71: Recovery plan



AFFORDABILITY

Construction affordability for Developing Countries is one of the main issues associated with sustainable construction and sustainable development.

Despite international awareness of sustainable construction, the cost rates for construction activities and resources have been continuously increasing. Due to these increases, the approaches to be used to achieve sustainable construction through efficient and affordable techniques can be difficult to determine but can prove to be effective in the long run.

Energy-efficient buildings involve lower financial risks, as they are economical in terms of the operational costs involved which increases the belief amongst the stakeholders.

Also, by addressing important issues such as thermal comfort, visual comfort and indoor environmental quality, there is an increased resale value, and rental value and hence the return on investment becomes much faster.

Green buildings also attract loans at a lower rate of interest and a faster sanctioning process. These factors play a major role in funding for the execution of the project.

Although the proposed cost of the project is more than the baseline cost, the total operational cost is much lesser than the baseline project. This has been achieved by improving the building's performance through various strategies mentioned below. The Proposed case total cost is 3.7% higher than that of the baseline cost.




Fig 72: Operation costs and financial breakups




Fig 73: Comparison of baseline and proposed building



Cost-effective strategies:






Figure 74: Maintenance cost (AMC) over 10 years for VRF v/s Radiant cooling



- Although the initial cost of radiant cooling is higher than VRF system, the maintenance cost is lesser by 54.6% and hence this helps in reducing the life cycle cost
- By using AAC blocks in the proposed case design instead of bricks, the dead load reduces by 58% and the cost per sqm. reduces by 39%

Figure 75: Radiant cooling v/s VRF

- Efficient planning to reduce circulation space by providing a single East-West corridor helps to increase the workspace area and in turn helps in the growth of the company.
- Since the service cores are limited to two corners, the functioning of the system is not disturbed.
- Healthier workspace with improved daylight facility and better indoor environmental quality reduces the cooling and lighting loads. Hence, the overall HVAC cost also reduces. This also, improves the productivity of the staff.




Fig 76: Comparison of Brick and AAC costing and weight




Fig 77: Corridors Layout

Main East-West corridor and secondary and tertiary corridors improve the circulation and communication in the workspace.



SCALABILITY & MARKET POTENTIAL

Chennai is home to more green buildings than any other city in the country, 42 of the 212 structures in India that are certified as eco-friendly by the Indian Green Building Council (IGBC) are in Chennai. Mylapore neighbourhood of Chennai is the central part and the cultural hub of the city. The proximity to the railway line enables easy accessibility and an increased public footprint. Other office and commercial buildings in a hot and humid climate.

Analysis of user/customer group -

- Office employees (1:1 - Male: Female ratio) of parent company
- Office employees (1:1 - Male: Female ratio) of rental/ lease company
- Maintenance and service support

Potential target market -




Fig 78 : Potential Target Market



Fig 79 : Irresistible Staircase view

The current proposal has evolved through scrutinizing of the design iterations and simulations, with the potential to be the prototype model for an office building located at similar climatic region and context. The proposal caters to the current needs of the office space market & the needs of occupants at larger scale irrespective of being client specific.

By keeping this proposal as a prototype, with minimal changes as per the requirements, this building can be adapted to suit the needs of users in similar (Hot & Humid) climatic conditions, and scale irrespective of its typology due to the open floor plan proposal.

Apart from the building's potential to scale up, the two innovations proposed by the team- Terracotta modules, Noise Absorbing Panels have the potential to be market products.



TERRACOTTA MODULES:

With the standard block size being 300mm X 300mm with a 150mm X 150mm puncture for airflow, the modules can be customized as 200mm X 200mm with 100mm X 100mm airflow punctures. The cost of these blocks ranges from Rs.50-80 based on the customized requirements.

With faster construction, these prefabricated blocks can be inbuilt into the 115mm thick walls, facing the direction of the wind, further adding aesthetically pleasing effects to the facade breaking the building's monotonous outlook.

NOISE ABSORBING MODULES` :

According to the 2018 report prepared by the Central Pollution Control Board (CPCB) of India, Chennai topped the list of noisiest metro cities in India. Chennai has an average noise level of 67.8dB during the day. Therefore, to combat this issue along with keeping Net-zero energy in mind we have developed a Modular product' that can be easily plugged onto any surface with incident noise energy across all climates and typologies of the structure are proposed by our team.



Fig 80: Exterior View




Fig 79 : Irresistible Staircase view

Required Component	Cost/Piece
Control board - Arduino Uno	270
LCD	220
Speaker Mic	100
Step-up Transformer	190
LED	90
Diodes	10
LDR Sensor	5
Circuit Wire	15
Total Circuit Cost	900

Table 26 : Cost analysis for circuit analysis

These modular products are designed in two modes - one as circuits and the other as panels for facades. The circuit system can be fixed at locations with noise potentials independent of buildings also. While the panels can be fixed on compound walls to light up the streets at night or incorporated into the building facades for aesthetics.



PITCH TO PROJECT PARTNER

SAT- PRANALI is a net-zero-energy-water building for Team Global Logistics' new regional office in Chennai. The building provides tenants/owner-based office spaces for a lease with a total built-up area of 2289.80 sqm. The building is designed to achieve optimal comfort throughout the year by using various strategies to improve daylighting and indoor air quality.

The building has a cut-out for natural light with a self-shading staggered west facade, the building is stacked up one floor above the ground. thermal comfort is achieved by wedging of the southern facade and green facade towards west and east. northern side has a recess for maximum daylight, The eastern facades are kept semi-permeable with green walls to allow max. airflow into the building.

A detailed climatic study was conducted to understand the combination of strategies that could be adopted to enhance the building's performance and achieve 100% comfortable operational hours.




Fig 81 : Exterior View

The proposed cost of construction is **Rs. 7.16 Cr** which is **3.7%** greater than the base case cost of construction which is **Rs. 6.64 Cr**






Fig 82: Flow chart of green building

Terracotta blocks that taper into a void help reduce the air temperature which in turn reduces the cooling load. These blocks are placed along the wind direction. It enables faster construction and adds character to the facade.

Piezoelectric system: NOISE BASED POWER BANKS are panels on facades that absorb sound and convert it into electrical energy which can be used for various purposes during construction and post-construction and also can act as a backup option when stored in batteries.





REFERENCES

- ASHRAE Standard 55-2017, Thermal Environmental Conditions for Human Occupancy
- ASHRAE Standard 90.1-2016, Energy Standard for Buildings Except Low-Rise Residential Buildings
- Bureau of Indian Standards, 2016. NATIONAL BUILDING CODE OF INDIA VOL.1 & 2, 2016. Government of India
- Ministry of Energy Efficiency. (2017) ECBC Building Guide.
- Ministry of Energy Efficiency. (2017) Energy Conservation Building Guide
- GRIHA Council and The Energy and Resources Institute. (2019) GRIHA Abridged Manual
- Ernst Neufert. (2012) Architect's Data.
- Tamil Nadu Combined Development and Building Rules, 2019
- <https://bullittcenter.org/vision/message-from-denis-hayes/>
- <https://www.wbdg.org/additional-resources/case-studies/bullitt-center>
- https://energyplus.net/weather-location/asia_wmo_region_2/IND/IND_Chennai-Madras.432790_ISHRAE

